



Ga Tech Campus Fire Panel Evaluations 2018

Building	Panel Type	Model #	Manu.Date	Wiring Cond	Obsolete	# of Initiating	#Notification	# SLC Cards	SLC Availability	Expansion
Broadband Inst. Lab #152	Digital Monitoring	XR100		Good	No	4	3	0	Thinking this is Security	
676 Marietta St #158	EST	EST2	270212 Rev.3	Good	Yes	59	31	1	33 Detectors available	Expandable 1 SLC 92/92
Army ROTC Office #23A	EST	EST 2	270212 Rev 4.0	Good	Yes	18	5	1	141 Detectors /155 mod	Replace panel
Business Services #164	EST	EST 2	Rev .03 37/00	Good	No	63	42	1	33 Detectors/53 modules	Not Expandable
EBB #195	EST	EST 3	14296	Good	No	183	156	3	2308 Points available	Max points 2500
JS Coon#145	EST	EST2	EST190143 V.320	Good	No	192	113	2	20 Available Detectors	Not Expandable
Klaus #153	EST	EST3 3-CAB210	270495 Rev 4.0	Good	No	567	372	4	1890 points available	up to 2500 points
Mason #111	EST	IO500	7160504-04	Good	No	252	97	2	19 Detectors /187 Mod	Non Expandable
Montgomery Knight	EST	QuickStart	2616-4 7990007-04	Good	Yes	14	8	Zone Panel	89Detectors/96 Mod	Not expandable
MRDC#135	EST	EST3 3-CAB210	Rev 2.0	Good	No	145	71	3	2365 points available	2500 Max Points
Nara Food Processing @159	EST	EST2	20311003 541198	Good	Yes			1	96/94	Expandable 96/94
OIT #23 A/B	EST	EST2	270212 V 4.0	Good	Yes	18	5	1	82 Detectors/90 Mod Available	Expandable 1 Loop 96/94
Research Admin #153	EST	EST2	387132 Rev 4.0	Good	Yes	126	57	1	24 Detectors/37 Mod	Expandable 1SLC 92/92
Skiles #2	EST	ET3 3-CAB210	270495 Rev 5.0	Good	No	321	266	4	2154 Points available	up to 2500 points
Student Center Commons 114	EST	EST2	190142 V2.3	Fair	Yes	139	65	2	76 Detectors /167 Mod Available	Non Expandable
Student Health Building	EST	EST2	190142 V 2.40	Good	Yes	145	39	2	47 Detector/147 Mod Available	Non Expandable
TEP II #780	EST	EST3 3-CAB210	Rev 2.0	Good	No			1	No report	Max 2500 points
EST #147	EST	EST IO Series	RP18B v4.0	Good	No			2	250 devices	Expandable to 1000
Kirk R Landon #791	EST	EST2	270212 Rev 4.0 02.19w	Good	Yes	65	25	1	31 Detectors /69 Modules	Not Expandable
NARA Techway #136	EST	Quickstart	06w19:09	Good	Yes	73	21		177 Detectors	Expandable 3 loops 250 each
Records Warehouse #838	EST	Quickstart	DEV- 1206	Good	Yes	25	9	1	225 Points available	Can add 3 loops
College of Computing #50	Faraday	MPC - 7000		Good	No	228	106	4	780 points /4 SLC	Non Expandable
Chapin Building #25	Firelite	MS-9600UDLS	3/2013 4813	Good	No	73	22	1	98 Detectors /146 Mod	Expandable 1 SLC 159/159
811 Marietta St	Firelite	9600 UDLS	9600LSv6.2 (11/2014)	Good	No	135	50	2	183 Detectors	Not expandable
8328 West Peachtree #178	Firelite	MS 9600UDLS	03/22/2016 9600LSv6.2	Good	No	148	66	1	32 Detectors /139 Modules	Add 1 SLC for 318 points
Alumni house #3	Firelite	MS-9200UDLS	9200UDV 5.0 2211	Fair	No	143	45	1	63 Detectors /110 Mod	Expandable 1 SLC 159/159
Beringause #46	Firelite	MS-9050UD	MS 9050 V2.1	Poor	No	22	18	1	27 Points available	Not Expandable
Couch Building #115	Firelite	MS-9600ULS	Version 6.2	Good	No	183	81	2	135 Detectors available	Not Expandable
Habersham House #137	Firelite	9600UDLS	9600LSv6.2 (11/2014)	Good	No	116	54	1	43 Detectors	Is expandable 1 SLC Card
Habersham House #137	Firelite	9600UDLS	9600 LS V6.2 11/2014	Good	No	116	54	2	517 points available	Not Expandable
Human Resources #142	Firelite	MS-9050UD	MS9050v4.1	Good	No	22	25	50 Point Only	28 available	This is a single SLC panel no Expansion
ISYE- Annex #57	Firelite	9600LSV4.3	Serial# 061411-1128	Good	No	25	10	1	134 Detectors Avail.	Expandable to 636 addressable points
ISYE Groseclose #57	Firelite	MS-9600	V2.1	Good	No	47	15	1	112 Detectors available	Add 1 SLC for 318 points
Rich Chiller Plant	Firelite	MS-25		Fair	Yes	10	2	25 points only	15 Available	Not expandable
School Of Arch. #76	Firelite	MS-9600	MS9600V2.6	Good	No	47	17		130 Detectors / 142 Mod	Not Expandable
Van Leer #85	Firelite	MS-9600UDLS	00100634 2915	Good	No	57	27	Zone Panel	Zone	Replace devices to addressable
Challenge Course	FireShield	FSP502 (G/R)	7990160	Good	No	3	5	5	5 Zone	10 Zones
Bio Medical Engin. #165	Johnson Control	IFC-640	8F- 9599	Good	No	210	181	2	177 Detectors/ 233 Mod	Not Expandable
EHS Bldg 187	Johnson Control	IFC-640	ACM-2	Good	No	100	57	2	218 Detectors Available	Add 1 SLC for 318 points
O'Keefe Building	Notifier	640	5635/cs118	Good	No	342	176	2	18 Detectors available	Non expandable 2 SLC Loops @318/318
NARA Structure Lab #149	Notifier	AFP-200	Dec-98	Good	Yes	39	30		60 Detectors/ 83 Mod	Not expandable
831 Marietta St	Notifier	NFS320	N62 v21.0	Good	No	21	46	1	148 Detectors/ 151 Modules	318 Max Points
Academy Of Medicine 198	Notifier	NFS-320	CPS V2.0	Good	No	98	37	1	82 Detectors /133 Mod	Expandable 1 SCL 318 points
Baker #99	Notifier	AMG640	JNCA-2	Good	Yes	18	5	1	636 points	Replace Panel
BOGGS	Notifier	640	Rev L Oct 12, 2009	Good	No	286	141	2	51 Detectors /301 mod	Not expandable
Bungar Henery	Notifier	AFP-400	AFP4R36	Good	Yes	183	67	2	44 Detectors/ 144 Mod	Not Expandable
Carnegie Building #36	Notifier	NFS320	410	Good	No	64	34	1	111 Detectors/142 Mod	Expandable 1 SLC 159/159
Cherry Emerson #66	Notifier	AFP-200	Sep-98	Good	Yes	124	40	1		Replace Not expandable
Cobb Building 3 # 803	Notifier	NFS 640	NFS-640 CPSV2.0	Good	No	228		2	90 Detectors	Not Expandable
Cobb Building 1	Notifier	NFS 320	CPS V 1.0 4110	Good	No	31		1	128 Detectors	Not Expandable
Cobb Building 5 #805	Notifier	NFS 320	NFS -320/ CPSV2.0	Good	No	49	32	1	110 Detectors /139 Mod	Not Expandable
Cobb County building 4	Notifier	NFS 320	CPS V1.0 4010	Good	No	39		1	120 Detectors Available /100+ Mod	Non Expandable
College of Management #172	Notifier	NFS -3030	1504	Good	No	322	359			
Economic Development #173	Notifier	NFS2-640	N62v11.03	Good	No	138	99	1	49Detectors/114 Mod	Add 1 SLC for 318 points
GTRI North #611	Notifier	AFP-400	ECN-96-480	Good	Yes	140	#VALUE!	1	19 detectors available	Non Expandable
Howey Physics 84	Notifier	AFP 400	AFP4R2.2 50140 Rev.A	Good	Yes	200	78	2	118 Detectors /318 Mod	Non Expandable
IBB #146	Notifier	AM640	5635/CS118	Good	No	110	180	2	208 Detector point /159 Mod	Not Expandable
LOVE (MRDC11) #144	Notifier	AM2020	AM2020	Poor	Yes	155	172	2	61 mod /100Detectors	Not Expandable

