

Building Name: GLC –Verizon Cell Site
Building #: 170
Occupancy Type: Business
Construction Type: IIB

Floor & Room #: Roof
Department: OIT
Budget: N/A
Type of Review: Construction Plan Review

Project Manager: Bill Lawrence
Architect / Engineer of Record: Robert Suggs III
Construction Manager:

Aim Project Number: CEST-95-2015

Reviewer: Labbe
Disposition: Approved

Date Received: 5/21/2015
Date Completed: 7/7/2015

Status Statement

Note: Verizon antenna project on the roof top of GLC.

Review Comments

1. Need an additional set of plan for Job-site copy. (bind and stapled sets please)

General Note:

1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection_request.php
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/hot_work.php

Additional Requirements: (as needed)

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System

3. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2015-CP-112

Thank you,

Georgia Tech Fire Safety Office