

Building Name: Love Manufacturing Bldg 3rd Floor
Building #: 144
Occupancy Type: Business
Const Type: Choose an item.

Floor & Room #: 3rd Floor
Department: Cary Ogletree
Budget: \$400,000
Type of Review: Construction Plan Review

Project Manager: Bill Oswell
Architect / Engineer of Record: WSP
Construction Manager: Liz Punch (TBD)

Aim Project Number:0236-2015

Reviewer: Redman
Disposition: Approved with additional requirements

Date Received: 10/12/2015
Date Completed: 3/8/2016

Status Statement

Note: The renovation of the Love Building Hatzell Lab.

Review Comments:

1. Page EL 101 add 3 emergency lights per red-line comments.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements: (as needed)

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2015-CP-213

Thank you,

Georgia Tech Fire Safety Office