

Building Name: Holland 480V Upgrade  
Building #: 26  
Occupancy Type: Industrial  
Construction Type: IIB

Floor & Room #: Building  
Department: Facilities  
Budget: \$1,400,00  
Type of Review: Construction Plan Review

Project Manager: David Chandler  
Architect / Engineer of Record: Spencer Bristol Engineering  
Construction Manager: Rod Moore

Aim Project Number: 0287-2015

Reviewer: Labbe  
Disposition: Approved

Date Received: 11/4/2015  
Date Completed: 1/21/2016

### **Status Statement**

Note: Holland power plant upgrade.

### **General Note:**

1. Inspection requests: [http://www.ehs.gatech.edu/fire/inspection\\_request.php](http://www.ehs.gatech.edu/fire/inspection_request.php)
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/hot\\_work.php](http://www.ehs.gatech.edu/fire/hot_work.php)

### **Inspections Required:**

1. Pre-Construction Meeting (This is a meeting with the Fire Marshal to discuss construction site layout, construction safety, and plan details with associated inspection requirements)
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

### **Permits Issued:**

1. Construction / Interior Renovation: 2015-CP-227

Thank you,

Georgia Tech Fire Safety Office