

Building Name: Marcus Nanotech Phases V & VI [FA]
Building #: 181
Occupancy Type: Business
Const Type: IIB

Floor & Room #: Floors 1, 2 and 4
Department: IEN
Budget: \$5,000,000
Type of Review: Fire Alarm Review

Project Manager: John DuConge
Architect / Engineer of Record: WSP/ Smith Carter
Construction Manager: John DuConge

Aim Project Number: C002-2015

Reviewer: Labbe
Disposition: Approved with additional requirements

Date Received: 11/17/2015
Date Completed: 1/28/2016

Status Statement

Note: Fire alarm modifications as part of phase 5 and phase 6 of the Nano building build-out

Review Comments:

1. Sheet FA-03, Add smoke detectors to: 2122A, 2122, and 2124A
2. Sheet FA-04, Add smoke detectors to: 4105, 4106, 4130, 4114

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

Permits Issued:

1. Fire Alarm: 2015-FA-242

Thank you,

Georgia Tech Fire Safety Office