

Building Name: EDB GT Foundation [CP]
Building #: 173
Occupancy Type: Business
Const Type: IIB

Floor & Room #: Fourth Floor
Department: [Click here to enter text.](#)
Budget: [Click here to enter text.](#)
Type of Review: Construction Plan Review

Project Manager: Eric- SWA
Architect / Engineer of Record: Liz Punch
Construction Manager: Liz Punch

Aim Project Number:0176-2016

Reviewer: Redman
Disposition: Approved with additional requirements

Date Received: 3/24/2016
Date Completed: 3/29/2016

Status Statement

Note: New doors to be installed at the elevator lobby at the EDB GT Foundation Building.

Review Comments:

1. A phone will be required in the elevator lobby for two way communication to trained emergency services personnel.
2. Door shall release in accordance with Life Safety Code 7.2.1.6.3 in its entirety.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

Permits Required:

1. Construction / Interior Renovation

Permits Issued:

1. Construction / Interior Renovation 2016-CP-076

Thank you,

Georgia Tech Fire Safety Office