

Plan Review Summary

Building Information

Project Name:	Pettit Agarwai Lab Reno	Floor & Room #:	3rd Floor, Multiple Rms
Building #:	146	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$240,000
Construction Type:	Choose an item.	Type of Review:	Construction Plan

Project Management

Project Manager:	Maria del Mar Ceballos
Architect/Engineer of Record:	Maria del Mar Ceballos
Construction Manager:	Maria del Mar Ceballos
Aim Project Number:	0041-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	11/23/2016
Disposition:	Approved	Date Completed:	2/1/2017

Status Statement

Note: A lab renovation in the Pettit building involving the Agarwai Lab.

Review Comments:

1. Approved as submitted after extensive code reviews and materials compliance information received.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2016-CP-276