

Plan Review Summary

Building Information

Project Name:	Gutekunst Lab	Floor/Room #:	1st Floor
Building #:	167	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$500,000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	DLS La Consultants/Craig Free
Construction Manager:	Kynthia Gaines
Aim Project Number:	0005-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	12/22/2016
Disposition:	Approved	Date Completed:	2/10/2017

Status Statement

Note: The supplemental submittal of the flammable liquids cabinet.

Review Comments:

1. Approved as submitted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2016-CP-296