

Building Name: Baker Fire Alarm Replacement [FA]  
Building #: 099  
Occupancy Type: Business  
Const Type: Choose an item.

Floor & Room #: Entire Building  
Department: GTRI  
Budget: 50,000  
Type of Review: Fire Alarm Review

Project Manager: Brian Clarke  
Architect / Engineer of Record: Johnson Controls  
Construction Manager: N/G

Aim Project Number:N/G

Reviewer: Click here to enter text.  
Disposition: Choose an item.

Date Received: 2/15/2016  
Date Completed: Click here to enter a date.

### **Status Statement**

Note:

### **Review Comments:**

1.

### **General Note:**

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### **Additional Requirements: (as needed)**

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed location Designation

### **Plan / Shop Drawings Required:**

1. Fire Suppression
2. Fire Alarm

### **Inspections Required:**

1. Pre-Construction Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc)
9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

**Permits Required:**

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

**Permits Issued:**

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Thank you,

Georgia Tech Fire Safety Office