

Building Name: Harris Residence Hall
Building #: 011
Occupancy Type: Dormitory
Const Type: IIB

Floor & Room #: All
Department: GT Housing
Budget: Not available.
Type of Review: Construction Plan

Project Manager: Spencer Sheffield
Architect / Engineer of Record: Fisher Engineering
Construction Manager:

Aim Project Number:0178-2016

Reviewer: Redman
Disposition: Declined

Date Received: 3/21/2016
Date Completed: 4/6/2016

Status Statement

Note: Fire alarm replacement at Harris Residence Hall.

Review Comments:

1. The 90% design layout is approved as submitted.
2. Provide device specification cut sheets and details.
3. Provide battery calculations for new system.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Thank you,

Georgia Tech Fire Safety Office