

Plan Review Summary

Building Information

Project Name:	O'Keefe Bldg Renovation [DEMO]	Floor & Room #:	1 & 3
Building #:	033	Department:	Facilities
Occupancy Type:	Business	Budget:	\$3,555,000
Construction Type:	IIB	Type of Review:	Demolition Review

Project Management

Project Manager:	Reagan Donley
Architect/Engineer of Record:	Smith Dalia – Craig Wertz
Construction Manager:	Carla Barbour
Aim Project Number:	C0102-2015

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	12/1/2016
Disposition:	Approved	Date Completed:	12/13/2016

Status Statement

Note: The O'keefe renovation and demo for the facilities group.

Review Comments: Revised Site Construction Plan Notes 12/13/2016.

1. Dumpster must be a minimum of 20-feet from structure.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting

Permits Issued:

1. Demolition 2016-DP-294