
Plan Review Summary

Building Information

Project Name:	GT Campus Warehouse Fire Alarm Plan	Floor/Room #:	Designated area over HPS
Building #:	882	Department:	Campus Services
Occupancy Type:	Industrial	Budget:	\$50K
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Mark Major
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0011-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	7/14/2016
Disposition:	Approved	Date Completed:	7/28/2016

Status Statement

Note: A Fire Alarm modification over the High Piled Storage Racking as part of the Warehouse renovation project.

Review Comments:

1. All devices must match existing devices and sync in accordance with NFPA 72.
2. All Alarm Tests must be approved by Georgia Tech Fire Marshal's Office. Occupant notification must be posted on all exterior entry / exit doors notifying occupants of testing within 24 hours of test being conducted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2016-FA-181