

Building Name: CRC Relocate Water Curtain Sprinkler
Building #: 160
Occupancy Type: Other
Const Type:

Floor & Room #:
Department:
Budget:
Type of Review: Fire Suppression Review

Project Manager: Spencer Sheffield
Architect / Engineer of Record: All Star Fire LLC
Construction Manager:

Aim Project Number:N/A

Reviewer: Labbe
Disposition: Approved

Date Received: 4/20/2016
Date Completed: 4/29/2016

Status Statement

Note: Renovation work requiring sprinkler head relocate and adjustments in order to provide adequate fire protection. GTFISO MRR Project.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc)

Permits Issued:

Fire Suppression: 2016-FS-094

Thank you,

Georgia Tech Fire Safety Office