

---

## Plan Review Summary

---

### Building Information

Project Name:	Bunger Henry DGMS & Fire Alarm Upgrades	Floor/Room #:	N/A
Building #:	086	Department:	Facilities / EH&S
Occupancy Type:	Business	Budget:	\$650,000
Construction Type:	IIB	Type of Review:	Fire Alarm Review

### Project Management

Project Manager:	Greg Spiro
Architect/Engineer of Record:	Exp/Regina Ndayou Nana
Construction Manager:	N/A
Aim Project Number:	CEST-96-2017

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/9/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/22/2017

### Status Statement

Note: The Georgia Tech DGMS and fire alarm system upgrades at Bunger Henry

### Review Comments:

1. Provide battery calculations for fire alarm and DGMS system with shop drawing's.
2. Provide manufacture specification sheets on all devices for the fire alarm system and the DGMS system.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed location Designation

### Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm / DGMS – 2017-038-Bid level drawings. NOT FOR PERMITTING.