
Plan Review Summary

Building Information

Project Name:	Solar Roof Array	Floor/Room #:	Roof
Building #:	086	Department:	College of Engineering
Occupancy Type:	Other	Budget:	\$41,061
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Stefan King
Construction Manager:	N/A
Aim Project Number:	0062-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/9/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/6/2017

Status Statement

Note: The addition of Solar array on the Bunger Henry roof Top.

Review Comments:

1. Sheet E-1 Provide current adopted Electrical Code NFPA 70 (2011).
2. Sheet E-2 Provide Equipment Markings in accordance with International fire code Chapter 6 Section 605.11.1.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2017-CP-002
-