

Plan Review Summary

Building Information

Project Name:	Pettit MIRC Elevator Renovation	Floor/Room #:	N/A
Building #:	095	Department:	FAC
Occupancy Type:	Business	Budget:	\$400,000
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Scheffer Grant
Construction Manager:	Corey Pressley
Aim Project Number:	100-2015

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/30/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/16/2017

Status Statement

Note: The renovation of the elevator in the Pettit Building.

Review Comments:

1. All penetrations in the shaft walls must be sealed in accordance with IBC.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2017-CP-029