Plan Review Summary

955 Fowler Street NW, Room 301B

Atlanta, Georgia 30318 (P) 404-894-FIRE (3473) (E) fire@ehs.gatech.edu

	Building Informa	ation	
Project Name:	Tech Tower EVPR / Provost Offices	Floor/Room #:	Ground Level
Building #:	035	Department:	Registrar Suite
Occupancy Type:	Business	Budget:	\$550,000
Construction Type:	IIIB	Type of Review:	Construction Plan Review
	Project Manage	ment	
Project Manager:	Liz Punch		
Architect/Engineer of	Record: Eric Clementi, SWI		
Construction Manage	er: Liz Punch		
Aim Project Number:	0133-2017		
	Reviewer Inform	ation	
Reviewer Name:	Cary Redman	Date Received:	2/6/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/17/2017
Status Statement	EVPR / Provost Offices renovation.		
			7
Review Comments:			

1. Provide manufacture detail sheets on all fire stopping.

Georgia Environmental Tech Health & Safety

Fire Safety

- 2. Exit signs and emergency lighting will need to be field verified upon site inspections.
- 3. Fire dampers must be accessible and labeled for observation and testing.

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

- 1. Fire Emergency Response Plans
- 2. Red Book Completion and Fixed location Designation

Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

Inspections Required:

- 1. Pre-Construction Meeting
- 2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
- 3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- Fire Suppression System
 Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2017-CP-033

