
Plan Review Summary

Building Information

Project Name:	Paper Tricentennial Building Boiler Room Ventilation	Floor/Room #:	Ground, Boiler Room
Building #:	129	Department:	Facilities O & M
Occupancy Type:	Business	Budget:	\$30,000
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Sam Dahdah
Architect/Engineer of Record:	Sam Dahdah
Construction Manager:	N/A
Aim Project Number:	223-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/10/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/21/2017

Status Statement

Note: A ventilation upgrade at the Paper Tricentennial Building Boiler Room.

Review Comments:

1. Fire damper must be accessible and labeled accordingly. Fire damper testing will be at the 80% inspection.
2. Provide fire stopping manufacturer details and sheets to the penetration to the fire wall.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2017-CP-040