

Plan Review Summary

Building Information

Project Name:	Van Leer Robotarium	Floor/Room #:	261
Building #:	085	Department:	Electrical & Computer Engineering
Occupancy Type:	Business	Budget:	\$317,000
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Bart Mc Dearmon
Construction Manager:	Corey Pressley
Aim Project Number:	0280-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/24/2017
Disposition:	Approved	Date Completed:	3/13/2017

Status Statement

Note: The construction of the Van Leer Robotarium addition.

Review Comments:

1. Addendums for fire stopping/spray approved as submitted. The contractor shall 3rd party testing on all spray material for adequate spray application.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete,
5. commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2017-CP-46

