
Plan Review Summary

Building Information

Project Name:	Paper Tricentennial Replace Boiler #2	Floor/Room #:	1st Floor
Building #:	129	Department:	Facilities O&M
Occupancy Type:	Business	Budget:	\$270,000
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Sam Dahdah
Architect/Engineer of Record:	Sam Dahdah
Construction Manager:	N/A
Aim Project Number:	223/2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/28/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/17/2017

Status Statement

Note: A new boiler to replace Boiler #2.

Review Comments:

1. Provide manufacture specifications for boiler.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2017-CP-47
-