# **Plan Review Summary**

955 Fowler Street NW, Room 301B

Atlanta, Georgia 30318

(P) 404-894-FIRE (3473) (E) fire@ehs.gatech.edu

Project Management
Budget: \$353,000 Type of Review: Construction Plan Review
Type of Review: Construction Plan Review
Project Management
Reviewer Information
Date Received: 3/6/2017
Date Completed: 3/17/2017

# Status Statement

Georgia

Tech

**Fire Safety** 

Note: A renovation of 2 data rooms in the COC converting into 2 offices and a meeting room.

Environmental Health & Safety

#### **Review Comments:**

1. Approved as submitted.

#### General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot\_work

#### Plan / Shop Drawings Required:

- 1. Fire Suppression
- 2. Fire Alarm

### **Inspections Required:**

- 1. Pre-Construction Meeting
- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

# Permits Required:

- 1. Fire Suppression System
- 2. Fire Alarm

#### Permits Issued:

1. Construction / Interior Renovation 2017-CP-051