

Plan Review Summary

Building Information

Project Name:	Office Build-out for Cubicles 165A 165B	Floor/Room #:	162, 165A, 165B, 169
Building #:	164	Department:	Business Services
Occupancy Type:	Business	Budget:	43, 162.35
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Elvia Lam
Architect/Engineer of Record:	Elvia Lam
Construction Manager:	
Aim Project Number:	0157-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/24/2017
Disposition:	Approved	Date Completed:	4/25/2017

Status Statement

Note: The cubical build out for the Business Services Building for rooms 165A and 165B.

Review Comments:

1. Approved as submitted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 25017-CP-066