

---

## Plan Review Summary

---

### Building Information

Project Name:	J. Allen Couch Restroom Renovation	Floor/Room #:	1st and 2nd Floor
Building #:	115	Department:	Facilities D&C
Occupancy Type:	Business	Budget:	N/A
Construction Type:	IIB	Type of Review:	Construction Plan Review

---

### Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record:	Brown Design Group – Coy Cooper
Construction Manager:	Mitchell Shelton
Aim Project Number:	0203-2017

---

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	4/5/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/25/2017

---

### Status Statement

Note: The renovation of the men's and women's restroom on the first and second floor at the Couch Building.

### Review Comments:

1. Must maintain fire suppression and fire detection during demolition.
2. A fire protection evaluation is required to determine proper audio visual and sprinkler head placement after new construction.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Construction / Interior Renovation 2017-CP-075
-