

Plan Review Summary

Building Information

Project Name:	EBB Takayama Lab Renovation	Floor/Room #:	4220, 4222, 4244/4226 A B, 4230, 4239, 4157
Building #:	195	Department:	College of Engineering
Occupancy Type:	Business	Budget:	N/A
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Maria del Mar Ceballos
Architect/Engineer of Record:	Lord Aeck Sargent, Jeff Burleson
Construction Manager:	Mitchell Shelton
Aim Project Number:	0110-2017

Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	4/24/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/2/2017

Status Statement

Note: Plans approved for permit on May 2, processed June 7 due to status change

Review Comments:

1. Sheet A-102, 3D Printer exhaust has not been resolved. The installation of a 3D printer is not approved as part of this permit. If a 3D printer is desired, a review of the type of printer and exhaust requirements is required.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation: 2017-CP-095