

---

## Plan Review Summary

---

### Building Information

Project Name:	GTRI Warner Robbins Field Office	Floor/Room #:	First Floor
Building #:	GTRI Office	Department:	GTRI
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Dennis Carter PE Concord Project Consulting Inc.
Construction Manager:	
Aim Project Number:	0033-2018

---

### Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	10/13/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	1/21/2018

---

### Status Statement

Note: Plans reviewed by UL Building Inspections, third party review.

### Review Comments:

1. Sheet A-1, The exit sign located by door 138A may be obstructed from view by shelving units identified as note A4. To be field evaluated.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation: 2017-CP-238
-