
Plan Review Summary

Building Information

Project Name:	Roe Stamps Field at CRC	Floor/Room #:	Field
Building #:		Department:	CRC
Occupancy Type:	Other	Budget:	
Construction Type:	Choose an item.	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Daktronics
Construction Manager:	
Aim Project Number:	0335

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	10/18/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	12/21/2017

Status Statement

Note: A digital board at Roe Stamps Field at CRC.

Review Comments:

1. Provide electrical certification documents upon completion of work.
2. Provide 3rd party inspection reports from engineers for the structure wind loads.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2017-CP-240
-