

---

## Plan Review Summary

---

### Building Information

Project Name:	U A Whitaker Mitchell Lab Renovation	Floor/Room #:	3232,3239
Building #:	165	Department:	
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Kynthia Gaines
Aim Project Number:	0367-2017

### Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	10/20/2017
Disposition:	Approved	Date Completed:	12/19/2017

### Status Statement

Note: Renovation of 700SF of space for the Mitchell Lab.

### Review Comments:

1. Sheet E101, Add fire alarm strobe in space 3232.
2. Sheet E101, There is not a legend for the electrical sheets. There is an F inside a box shown on the south wall. If this is a strobe it appears to be obstructed by a screen mounted on the same wall. A fire alarm strobe is required in this room.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed location Designation

### Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation: 2017-CP-243