

---

## Plan Review Summary

---

### Building Information

Project Name:	Mechatronics Lab College of Computing	Floor/Room #:	030
Building #:	050	Department:	
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Jeff Burleson
Construction Manager:	Bill Oswell
Aim Project Number:	210-2017

---

### Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	11/3/2017
Disposition:	Approved	Date Completed:	12/21/2017

---

### Status Statement

Note: Phase 2 of a two phase project in the College of Computing building. The space will be converted from wet chemical labs to small electronics lab space.

### Review Comments:

1. Emergency egress lighting will be confirmed during the final inspection. All walk/egress paths will need to have 1 Ft. candle lamination.
2. Fire alarm speaker/strobes are required in the lab areas. To be confirmed in the field.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation: 2017-CP-260
-