

---

## Plan Review Summary

---

### Building Information

Project Name:	Tech Square Parking Deck	Floor/Room #:	All Levels
Building #:	174	Department:	Parking and Transportation
Occupancy Type:	Storage	Budget:	\$80,000
Construction Type:	IIB	Type of Review:	Construction

### Project Management

Project Manager:	Danielle Powell
Architect/Engineer of Record:	Marion Parker / Timothy Haas & Associates
Construction Manager:	
Aim Project Number:	0068-2017

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	11/22/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/2/2018

### Status Statement

Note: Tech Square Parking Deck New Signage Plan.

### Review Comments:

1. All egress signage must comply with NFPA 101 Life Safety Code Chapter 7.10.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Pre-Construction Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Construction / Interior Renovation 2017-CP-270
-