
Plan Review Summary

Building Information

Project Name:	GLC Refresh of 334/335	Floor/Room #:	334, 335
Building #:	170	Department:	Professional Education
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Alison Gerstung/Amber Chellis-Omedo
Architect/Engineer of Record:	Amber Chellis-Omedo, Tony Gonzalez
Construction Manager:	Fenella Bryant
Aim Project Number:	0397-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	11/27/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	12/21/2017

Status Statement

Note: GLC Refresh of 334/335

Review Comments:

1. Sheet E102- Install smoke detectors in each room in accordance with local yellow book requirements.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2017-CP-271
-