
Plan Review Summary

Building Information

Project Name:	GTRI 1676 Family Restroom 114	Floor/Room #:	1 st floor, 114
Building #:	790	Department:	GTRI
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Carl Beasley
Architect/Engineer of Record:	Jon Jimenez, PE Concord Project Consulting, Inc.
Construction Manager:	Click here to enter text.
Aim Project Number:	0125-2018/2018-PRF-2582

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	12/11/2017
Disposition:	Approved	Date Completed:	2/8/2018

Status Statement

Note: The GTRI 1676 Family Restroom 114 renovation.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2017-CP-288
-