
Plan Review Summary

Building Information

Project Name:	Fulmer Underground Gas Pipe Replacement	Floor/Room #:	
Building #:	106	Department:	GT Housing
Occupancy Type:	Apartment Building	Budget:	\$150,000.00
Construction Type:	Choose an item.	Type of Review:	Construction

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Johnson Spellman & Associates
Construction Manager:	
Aim Project Number:	0152-2018

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	12/21/2017
Disposition:	Approved	Date Completed:	2/9/2018

Status Statement

Note: the Fulmer Underground Gas Pipe Replacement plan.

Review Comments:

1. All pipe must be inspected and pressure tested before being placed in service.
2. All piping penetrating walls must be sleeved and the annular space sealed up in accordance with Section 404 DCA IFGC Amendment.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Construction / Interior Renovation 2017-CP-302
-