	Plan I	Review Summary					
	Βι	uilding Information					
Project Name:	Fleet Parts Office	Floor/Room #:	Main Level	-			
Building #:	067	Department:	Facilities Fleet Services				
Occupancy Type:	Industrial	Budget:	\$50,000.00				
Construction Type:	IIB	Type of Review:	Construction				

955 Fowler Street NW, Room 301B

Atlanta, Georgia 30318

404-894-FIRE (3473)

### Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record	I: Coy Cooper/Brown Design Group
Construction Manager:	Mitchell Shelton
Aim Project Number:	0188-2018
	Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	12/21/2017
Disposition:	Approved	Date Completed:	2/9/2018

## Status Statement

<u>Georgia</u>

Tech

Fire Safety

Note: A Fleet Parts Office to be built in the existing fleet maintenance building.

### General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot\_work

Environmental Health & Safety

### Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

# Permits Issued:

1. Construction / Interior Renovation 2017-CP-304