

---

## Plan Review Summary

---

### Building Information

Project Name:	ERP Swing Space Renovation (Ph. 1)	Floor/Room #:	Entire Bldg.
Building #:	186	Department:	Facilities D&C
Occupancy Type:	Business	Budget:	\$865,000
Construction Type:	IIB	Type of Review:	Construction

---

### Project Management

Project Manager:	Liz Punch
Architect/Engineer of Record:	Schnieder Wright/Eric Clementi
Construction Manager:	Liz Punch
Aim Project Number:	0263-2017

---

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/29/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	<a href="#">Click here to enter a date.</a>

---

### Status Statement

Note: The ERP Swing Space Renovation phase 1.

### Review Comments:

1. Must maintain exit egress at all times during demolition and during construction.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Pre-Construction Meeting

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

### Permits Issued:

1. Demolition 2017-DP-071
-