
Plan Review Summary

Building Information

Project Name:	TSRB Microwave Chamber Demolition	Floor/Room #:	552
Building #:	175	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$9,000
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Liz Punch
Architect/Engineer of Record:	Veenendaal Cave, Robert & Henkte
Construction Manager:	Liz Punch
Aim Project Number:	0247-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/30/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/25/2017

Status Statement

Note: The demolition to Lab 552 in the TSRB.

Review Comments:

1. Must maintain fire suppression and fire detection at all times during demolition.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Demolition 20177-DP-073
-