

## Plan Review Summary

### Building Information

Project Name:	Boggs Renovation of EPR Lab B-81	Floor/Room #:	Basement; B-81
Building #:	103	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$120,000
Construction Type:	IIB	Type of Review:	Fire Suppression Review

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Fenella Bryant
Aim Project Number:	0079-2017

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/30/2017
Disposition:	Declined	Date Completed:	4/24/2017

### Status Statement

Note: The expansion of the existing sprinkler system in the Boggs building with the ERP renovation.

### Review Comments:

1. The scale on the plans do not match the drawings.
2. The existing main size is not shown on the plans.
3. No Georgia designer seal or NICET Stamp.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Alarm

### Permits Issued:

1. Demolition

- 2. ~~Construction / Interior Renovation~~
  - 3. ~~Fire Suppression System~~
  - 4. Fire Alarm
- 

