
Plan Review Summary

Building Information

Project Name:	Marcus Nanotechnology Cell Mfg. Facility	Floor/Room #:	Click here to enter text.
Building #:	181	Department:	Facilities D&C, O&M
Occupancy Type:	Business	Budget:	\$4,000.000
Construction Type:	IIB	Type of Review:	Construction

Project Management

Project Manager:	Carla Barbour
Architect/Engineer of Record:	Craig Wertz-Smith Dalia
Construction Manager:	Carla Barbour
Aim Project Number:	0242-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	8/4/2017
Disposition:	Declined	Date Completed:	9/20/2017

Status Statement

Note: A new cell manufacturing lab to be built in a vacant shell space in the Marcus Nanotechnology Building.

Review Comments:

1. Sheet A-111C- Observation glass shall not exceed 25% of the total fire rated wall.
2. Sheet A-111C- The Knock Out Panel at Column line C shall be the same rating of the corridor wall.
3. Sheet Q111- Identify hazardous materials storage cabinet on equipment plan.
4. Sheet EL111- Add emergency lighting fixtures to all lab areas.

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

Permits Issued:

1. Demolition
 2. Construction / Interior Renovation
 3. Fire Suppression System
 4. Fire Alarm
-