
Plan Review Summary

Building Information

Project Name:	Evo Event Bobby Dodd Stadium	Floor/Room #:	Bodacious Burgers Concession
Building #:	017	Department:	Auxiliary Services
Occupancy Type:	Business	Budget:	\$6,000
Construction Type:	IB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	None
Construction Manager:	Daniel Powell
Aim Project Number:	0174-2018

Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	12/14/2017
Disposition:	Declined	Date Completed:	2/5/2018

Status Statement

Note: Equipment addition to an existing concession at Bobby Dodd Stadium.

Review Comments:

- Professional design documents need to be prepared showing the following:
 - Equipment, existing and proposed are to be shown on base building drawings to scale and with sufficient detail for a code review.
 - Fire alarm drawings prepared by a professional, NICET 3 or higher. Professional, scalable documents required
 - Fire suppression system drawings are to be prepared by a GA licensed fire suppression designer. Professional, scalable documents required.
 - Hand drawn documents provided are not acceptable.

Plan / Shop Drawings Required:

- Fire Suppression
- Fire Alarm

Permits Required:

- Construction / Interior Renovation
 - Fire Suppression System
 - Fire Alarm
-