

Plan Review Summary

Building Information

Project Name:	Fire Alarm Upgrade	Floor/Room #:	All
Building #:	134	Department:	GT Housing
Occupancy Type:	Dormitory	Budget:	
Construction Type:	IIB	Type of Review:	Construction Plan Review

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Simplex
Construction Manager:	N/A
Aim Project Number:	0192

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/4/2017
Disposition:	Declined	Date Completed:	2/7/2017

Status Statement

Note: The Fire alarm System upgrade at the Fourth street apartments.

Review Comments:

1. Contractor must attach Fire Alarm Testing signs on all entry/exit doors during testing. These signs are furnished by the Fire Marshal's Office.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm 2017-FA-003