

Plan Review Summary

Building Information

Project Name:	O'Keefe Fire Alarm Replacement	Floor/Room #:	N/A
Building #:	033	Department:	Facilities D&C and O&M
Occupancy Type:	Business	Budget:	\$225,464
Construction Type:	IIB	Type of Review:	Fire alarm

Project Management

Project Manager:	N/A
Architect/Engineer of Record:	Johnson Spellman Associates – Leah Benincasa
Construction Manager:	Carla Barbour
Aim Project Number:	0204-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/10/2017
Disposition:	Approved	Date Completed:	3/17/2017

Status Statement

Note: A new fire alarm system with the renovation at the O'Keefe Building.

Review Comments:

1. Approved as submitted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Alarm 2017-FA-006