
Plan Review Summary

Building Information

Project Name:	Cherry Emerson Diggle Lab Renovation	Floor/Room #:	1st Floor: A101, A110, C101/103
Building #:	066	Department:	N/A
Occupancy Type:	Business	Budget:	N/A
Construction Type:	IIB	Type of Review:	Fire Alarm Review

Project Management

Project Manager:	Corey Pressley
Architect/Engineer of Record:	Elvia Lam
Construction Manager:	Corey Pressley
Aim Project Number:	0025-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/16/2017
Disposition:	Approved	Date Completed:	2/3/2017

Status Statement

Note: New fire alarm devices as part of an renovation at the Cherry Emerson Building.

Review Comments:

1. Approved as submitted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Alarm 2017-FA-016
-