

Plan Review Summary

Building Information

Project Name:	GTRI Advanced Manufacturing	Floor/Room #:	N/A
Building #:	N/A	Department:	GTRI
Occupancy Type:	Business	Budget:	N/A
Construction Type:	IIB	Type of Review:	Fire Alarm Review

Project Management

Project Manager:	N/A
Architect/Engineer of Record:	Lord AECK & Sargent
Construction Manager:	Frank Lamia
Aim Project Number:	N/A

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/26/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/15/2017

Status Statement

Note: A new fire alarm for the advanced Manufacturing Facility.

Review Comments:

1. Add smoke detection in office and corridors per Georgia Tech local requirements located in Section 283100 subsection C. Fire alarm systems shall be dedicated to smoke and fire detection, alarm, and related control functions. Do not use fire alarm systems to provide security alarms or other functions.
2. A 24 hour notice to building occupants shall be in place when any testing is going to be conducted. The fire safety office will supply proper signage for testing. Signage is to be placed on all entry / exit doors.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2017-FA-022