
Plan Review Summary

Building Information

Project Name:	CRB 679 Closed Room	Floor/Room #:	6th Floor, Suite 679
Building #:	790	Department:	GTRI
Occupancy Type:	Business	Budget:	
Construction Type:	IIB	Type of Review:	Fire Alarm Review

Project Management

Project Manager:	Carl Beasley / Brian Clarke
Architect/Engineer of Record:	Knight Architects, Inc.
Construction Manager:	N/A
Aim Project Number:	0306-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/6/2017
Disposition:	Approved	Date Completed:	2/17/2017

Status Statement

Note: The addition of fire alarm devices as part of the CRB Room 679 renovation.

Review Comments:

1. Approved as submitted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2017-FA-032
-