
Plan Review Summary

Building Information

Project Name:	IBB Agarwal Lab Renovation	Floor/Room #:	3rd Floor: 3119, 3120, 3127
Building #:	146	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$2,500
Construction Type:	IIB	Type of Review:	Fire Alarm Review

Project Management

Project Manager:	Maria Del Mar Ceballos
Architect/Engineer of Record:	N/A
Construction Manager:	Jennifer Disotell
Aim Project Number:	0041-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/3/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/24/2017

Status Statement

Note: IBB Agarwal Lab Renovation including new Fire alarm devices.

Review Comments:

1. All devices must be pretested before final inspection and testing.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2017-FA-049