
Plan Review Summary

Building Information

Project Name:	MS&E Silva Lab Renovations [FA]	Floor/Room #:	Ground Level
Building #:	167	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$304,000
Construction Type:	IIB	Type of Review:	Fire Alarm Review

Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Craer, Free, DKS Kat Consultants
Construction Manager:	Kynthia Gaines
Aim Project Number:	0057-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/16/2017
Disposition:	Approved	Date Completed:	3/28/2017

Status Statement

Note: the MS&E Silva Lab Renovations to include 8 new fire alarm devices.

Review Comments:

1. A pretest must be performed before a final inspection will be conducted.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2017-FA-61
-