
Plan Review Summary

Building Information

Project Name:	Van Leer Robotarium	Floor/Room #:	261
Building #:	085	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$317,941.00
Construction Type:	Choose an item.	Type of Review:	Fire Alarm

Project Management

Project Manager:	Corey Pressley
Architect/Engineer of Record:	All-Star Fire, LLC
Construction Manager:	Corey Pressley
Aim Project Number:	0280-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/17/2017
Disposition:	Approved	Date Completed:	3/22/2017

Status Statement

Note: A new fire alarm device installation with the renovation at Van Leer.

Review Comments:

1. Approved.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Alarm 2017-FA-065
-