

Plan Review Summary

Building Information

Project Name:	TSRB 2nd & 3rd Floor Renovation	Floor/Room #:	2nd & 3rd Floor
Building #:	175	Department:	College of Computing
Occupancy Type:	Business	Budget:	\$50,000
Construction Type:	IIB	Type of Review:	Fire Alarm Review

Project Management

Project Manager:	Liz Punch
Architect/Engineer of Record:	N/A
Construction Manager:	Liz Punch
Aim Project Number:	0236-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	4/5/2017
Disposition:	Approved	Date Completed:	4/26/2017

Status Statement

Note: New fire alarm devices as part of the renovation at the TSRB second and 3rd floors.

Review Comments:

1. Approved.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Alarm 2017-FA-081