
Plan Review Summary

Building Information

Project Name:	Alumni House Roof Renovation [FA]	Floor/Room #:	3rd Floor
Building #:	003	Department:	GT Facilities
Occupancy Type:	Business	Budget:	\$750.00
Construction Type:	VB	Type of Review:	Fire Alarm

Project Management

Project Manager:	
Architect/Engineer of Record:	Make 3, Jim Winer
Construction Manager:	Jennifer Disotell
Aim Project Number:	0163-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	4/13/2017
Disposition:	Approved	Date Completed:	4/27/2017

Status Statement

Note: A new tamper and valve as part of the 3rd floor and roof replacement on the Alumni House.

Review Comments:

1. Approved.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2017-FA-083
-