
Plan Review Summary

Building Information

Project Name:	Van Leer Fire Alarm Plans	Floor/Room #:	All Floors
Building #:	85	Department:	Campus and ECE
Occupancy Type:	Business	Budget:	\$8,100,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Gary Petherick
Architect/Engineer of Record:	David Yocun/BLDGS
Construction Manager:	Gary Petherick
Aim Project Number:	C0270-2015

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	10/25/2017
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/5/2018

Status Statement

Note: The Van Leer Fire Alarm Plans for renovation.

Review Comments:

1. All occupants shall be notified within 24 hours of fire alarm testing. Proper signage provided by the fire safety office will be required to be placed on entry/exit doors 24 hours prior to testing.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Pre-Construction Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2017-FA-248