

---

## Plan Review Summary

---

### Building Information

Project Name:	E-Beam Lithography Tool Enclosure Project	Floor/Room #:	First Floor-Clean Room
Building #:	181	Department:	IEN
Occupancy Type:	Business	Budget:	\$294,900
Construction Type:	IIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	GT-Kynthia Gaines
Architect/Engineer of Record:	GT-Sam Dahdah
Construction Manager:	GT-Kynthia Gaines
Aim Project Number:	0028-2018

---

### Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	12/11/2017
Disposition:	Approved	Date Completed:	2/2/2018

---

### Status Statement

Note: Fire alarm scope for a permitted construction project

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm 2017-FA-290
-